



आईआरईएल (इंडिया) लिमिटेड  
**IREL (India) Limited**  
(Formerly Indian Rare Earths Limited)  
(भारत सरकार का उपक्रम)  
(A Government of India Undertaking)



CIN : U15100MH1950GOI008187 Website : www.irel.co.in

ISO 9001: 2015, ISO 14001: 2015 & ISO 45001 : 2018 Company

**CORRIGENDUM: I Dated 12/11/2024**

Item/ Job Description	Design, Manufacture, Transportation, Supply, Installation, Testing and Commissioning of retrofit Emission control device on existing 750KVA DG at REEP of IREL (India) Limited, OSCOM.)
GeM Bid No.	GEM/2024/B/5523617 Dated: 22-10-2024

Following Changes are hereby made in the tender:

Sl. No.	Bid Document Page No.	In place of	To Read as
01.	5/10	<p><b>Buyer added Bid Specific Additional Scope of Work</b></p> <p>↓</p> <p><b>Document Title</b></p> <p>↓</p> <p><b>Click " View ":</b></p> <p>↓</p> <p><b>Technical Specification</b></p> <p><b>1. SCOPE OF WORK:</b></p> <p>c) Retrofit emission control system should be as per latest CPCB/NGT/OPSCB notification to achieve minimum specified particulate matter capturing efficiency of at least 70% in 5 mode D2 cycle. The emission control device/ Equipment must be tested over an ISO- 8178 5 mode D2 cycle for equivalent KVA rating at any one of the five Central Pollution Control Board (CPCB), Government of India accredited Lab/Development centre as below</p> <p>e) The RECD should be made with "<b>Filter-less Electrostatic Precipitator technology</b>"</p>	<p><b>Technical Specification</b></p> <p><b>1. SCOPE OF WORK:</b></p> <p>c) Retrofit emission control system should be as per latest CPCB/NGT/OPSCB notification to achieve minimum specified particulate matter capturing efficiency of at least 70%. The emission control device/ Equipment must be tested at any one of the Central Pollution Control Board (CPCB), Government of India accredited Lab/Development centre to be submitted.</p> <p>e) The RECD should be made with Filter-less ESP or any other latest technology and the output result of the RECD should be as per latest CPCB norms, irrespective of the manufacturer's technologies.</p>

All other terms and conditions of the tender shall remain unchanged. Please visit us at <http://irel.co.in>, and [www.gem.gov.in](http://www.gem.gov.in) for other details and further Corrigendum(s), if any.

-Sd/- DGM-Tech.(Purchase)